

**Egremont Board of Health**

**Thursday August 11, 2016, 10:25 am**

**In Attendance:** Charles Ogden, Dr. William Rose

**Also in Attendance:** Dr. Robert Furlong

**Recording:** Juliette Haas

- 1) The minutes from the July 21, 2016 were reviewed, corrected and approved.
- 2) **Hohman/93 Hillsdale Road** Georgann Farnum immediately submitted revised procedures letter, as per the request of the BoH. Also, an inspection of the facilities was immediately scheduled. Sandra reported that the facility is excellent, clean and their waste removal and cleaning procedures were also excellent.
- 3) **New Member Search** Heidi Zorn is unable to join board as this time. The board asked Juliette to contact Scott Race to see if he would be interested in joining.
- 4) **John Andrews Septic System** Juliette will write letter to Dan Smith at John Andrews on behalf of BoH to remind him that he must have his grease trap pumped once a month (per Title 5 code) and that his system is very old and needs maintenance in order to prolong its life.
- 5) **6 Main Street** Homeowner recently contacted BoH that his system is backing up/ponding. Homeowner was advised to limited use/water and upgrade immediately. Tank was pumped and Wilkinson Excavating performed a temporary repair. Perc was quickly performed and new system will be installed soon.
- 6) **Katz/4 Ridge Road** During final BoH inspection there was an issue with the float in pump chamber which didn't engage pump or alarm. Matter was completely fixed and resolved. Certificate of Compliance was issued.
- 7) Meeting adjourned at 10:45 pm. Next meeting is scheduled for August 25th at 10:00 am

*Approved 8/25/2016*

*JSHAas*