

Egremont Board of Health

January 19, 2017, 3:00 pm

Egremont Town Hall, Selectman's Office

In Attendance: Charles Ogden, Dr. William Rose, Ellen Maggio

Others Attending: Chris Tryon, Berkshire Geo-Engineering

Recording: Juliette Haas, Director

- 1) The minutes from the January 5 and January 11, 2017 minutes were reviewed and approved.
- 2) **Arce/167 Egremont Plain Road** Chris Tryon from Berkshire Geo-Engineering appeared before board and presented plans for septic upgrade at this property. The plans show the water line and sewer line crossing. To avoid this, board requested moving the location of the new septic tank. Chris stated as-builts maps will be provided to show new location of tank and water line. After full review, board approved a one foot reduction to estimated seasonal high groundwater variance request under maximum feasible compliance.
- 3) **John Andrews/Hillsdale Road** The DEP boil order remains as the required water testing has not been completed. The board asked for an update at the next meeting.
- 4) **New Egremont Well Regulations** Juliette will bring finalized copy of regulations for the board to sign at the next meeting.
- 5) **National Groundwater Awareness Week March 5 - 11, 2017** As much of the board's recent discussions have been on water quality and protection, Juliette will write on the topic in the next newsletter and will post something on the topic on the Egremont Posts and Neighbors Net.
- 6) **Past Board Members Plaque** The plaque was taken down about 5 years ago and was stored. The search will continue.
- 7) Meeting adjourned 3:38 pm. Upcoming meeting schedule: February 2nd and February 16th.

Approved
February 16, 2017
JS Haas